

Fire Test Certificate

Wednesday October 22nd, 2014

Supplier: Arrowsun Pty Ltd (35 Downard Street, Braeside, VIC 3195)

Sample Description: Wild Oak

Date Tested: October 2014 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: ISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

ISO 9239-1:2002	Wild Oak
Critical Heat Flux/Critical Radiant Flux*	3.8 kW/m ²
Smoke Value*	9 %.min
Penetration of flame through to substrate	Yes
Glowing	Yes
Smoldering	Yes

*Three test average value



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant

CV140839